IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR

MCDOWELL COUNTY PSD TIDEWATER, WV3302407

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 6/1/2026 and 6/30/2026, we failed to maintain an adequate chlorine residual concentration and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
41, FAILURE MAINTAIN MICROBIAL TREAT.(GWR) Failure to Maintain 4-log Treatment of Viruses, Free Chlorine Level Below Required Minimum	6/1/2026 to 6/30/2026

What happened? What is being done? (Describe corrective action)

The PSD failed to meet the required minimum chlorine reading set by the state. Resulting in this public notice. However, the adjustments have been made to correct this issue.

For more information, please contact Mavis Brewster (Contact name) at 304-297-2622 (Phone number)

Or 21901 Rocket Boys Drive Welch WV 24801 (Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **MCDOWELL COUNTY PSD TIDEWATER**

State Water System ID #: WV3302407 Date Distributed: 9-30-2026