IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR

MCDOWELL COUNTY PSD BRADSHAW, WV3302437

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 4/1/2024 and 6/30/2024, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
03, MONITORING, ROUTINE MAJOR **NITRITE** Results Not Reported	4/1/2024 to 6/30/2024

What happened? What is being done? (Describe corrective action)

A sampling schedule error occurred, and this sample was missed The PSD will continue to monitor Nitrite by provided sample schedule issued by the state to resolve the issue

For more information, please contact JARED R BREWSTER (Contact name) at 304-297-2622 (Phone number)

Or 21901 Rocket Boys Drive Welch WV 24801 (Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **MCDOWELL COUNTY PSD BRADSHAW**

State Water System ID #: WV3302437

Date Distributed: 10-15-24

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
MONITORING REQUIREMENTS NOT MET FOR

MCDOWELL COUNTY PSD BARTLEY, WV3302434

We are required to monitor your drinking water on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. Between 4/1/2024 and 6/30/2024, we failed to submit the required samples as indicated below and therefore cannot be sure of the quality of our drinking water during that time.

What should I do?

There is nothing you need to do at this time.

The table below lists the required monitoring and the compliance period.

Required Monitoring	Compliance Period
27, MONITORING, ROUTINE (DBP), MAJOR Failure to Monitor/Report Disinfectant By-Product Precursors (TOC and/or Alkalinity)	4/1/2024 to 6/30/2024

What happened? What is being done? (Describe corrective action)

The samples were pulled using the incorrect bottles required by the lab to preform the test, so we did not get any results. The next months samples have since been pulled and will continued to be monitored monthly

For more information, please contact JARED R BREWSTER (Contact name) at 304-291-2622 (Phone number)

Or 21901 Rocket Boys Drive Welch WV 24801 (Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **MCDOWELL COUNTY PSD BARTLEY**

State Water System ID #: WV3302434 Date Distributed: 10-15-24

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
Exceeded Maximum Contaminant Level (MCL) for Haloacetic Acids

MCDOWELL COUNTY PSD BARTLEY, WV3302434

Our water system recently violated a drinking water standard. Although this is not an emergency, you, as our customers have the right to know what happened, what you should do, and what we are doing to correct the situation.

We routinely monitor for the presence of drinking water contaminants. Test results for 7/1/2024 and 9/30/2024 show that our system exceeds the standard or maximum contaminant level (MCL) for Haloacetic Acids.

The average level of Haloacetic Acids over the last four quarters was 61.000000000µg/L at 17586 ROCKET BOYS DR location. The standard for Haloacetic Acids is 60.0µg/L.

What should I do?

You do not need to use an alternative (e.g. bottled) water supply. However, if you have specific health concerns, it is recommended that you consult with your doctor.

What does this mean?

This is not an immediate risk. If it had been, you would have been notified immediately. However, some people who drink water containing Haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

What happened? What is being done? (Describe corrective action)

The PSD has exceeded th MCL (Maximum Contaminant Level) on the HAA5 sampling. We will be ~~re~~ evaluating the treatment process and updating the flushing program to Correct the issue.

For more information, please contact JARED R BREWSTER (Contact name) at 304-297-2622 (Phone number)

Or 21901 Rocket Boys Drive Welch, WV 24801 (Mailing address)

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: **MCDOWELL COUNTY PSD BARTLEY** 9/18/2024

State Water System ID #: WV3302434 Date Distributed: 10-15-2024